

Skill name

Refrigeration and Air Conditioning

Criteria	Mark
A Component Fabrication	12.50
B Component and System Installation	20.00
C Electrical Installation	15.00
D Commissioning and Adjustment	17.50
E Electrical Fault Find and Repair	8.00
F Refrigeration Repair	10.00
G Refrigerant Recovery and Control	12.00
H Work Practices and Safety	5.00
I	

Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score
A1	Module A - Copper Fabrication	M M M M M M M M M M M J	Is the heat recovery coil and accessories as per specifications (D Fabricated heat recovery coil fit in support prepared by Festo(it g Is the length of the recovery coil as per measurements Is solenoid _____as per specifications (measurements, flow diagr Is access valve _____ as per specifications (measurements, flow d Is bend _____ as per specification (see standards)(measurement Is bend _____ as per specification (see standards)(measurement Fabricated copper tube is leak tight on first attempt IS Heat recovery coil fabricated and finished with in 150 minutes IS Heat recovery coil fabricated and finished with in 180 minutes Brazed joint #1 is made to acceptable standard (Copper to copper	0 1

		J	Brazed joint #2 is made to acceptable standard	2 3 0 1 2 3
		J	Brazed joint #3 is made to acceptable standard	0 1 2 3
		J	Brazed joint #4 is made to acceptable standard	0 1 2 3
		J	Brazed joint #5 is made to acceptable standard	0 1 2 3
		J	Brazed joint #6 is made to acceptable standard	0 1 2 3
Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score
B1	Module B - Major Components	M M M M	Compressor installed in specified location and securely fixed to c Liquid reciever installed as specified Suction accumulator installed as specified Fabricated copper coil installed in ice rink as specified	

B2	Module B - Refrigerant Controls	M	All pipework is installed within the boundaries of the supplied crad	
		M	Thermostatic expansion valve installed in correct location in syste	
		M	Capacity regulating valve installed in correct location in system, v	
		M	Pressure controls are piped as per specifications	
B3	Module B - Low Pressure Vapour Lines	M	Pressure controls are leveled and securely mounted to wall	
		M	All Suction, low pressure vapour lines are insulated	
		M	All bends of appropriate radius with no kinks	
		M	All pipe installed in vertical and horizontal planes and the pipe we	
		M	Installed pipework does not rub on any components when operat	
		M	Suction line is securely fastened using approved method	
		M	Nitrogen used to make all brazed connections	
		M	Suction low pressure vapour lines are set out so that these pipes	
		J	Brazed joint #1 is acceptable (copper to copper)	0 1 2 3
		J	Is brazed joint ____ on suction accumulator acceptable	0 1 2 3
B4	Module B - High Pressure Liquid Line	M	All bends of appropriate radius with no kinks	
		M	All pipe installed in vertical and horizontal planes and the pipe we	
		M	Installed pipework does not rub on any components when operat	
		M	Liquid line is securely fastened using approved method	
		M	Nitrogen used to make all brazed connections	
		J	Brazed joint #2 is acceptable (copper to copper)	0 1 2 3
		J	Is brazed joint ____ on liquid reciever acceptable	0 1 2

B5	Module B - High Pressure Discharge Line	M	All bends of appropriate radius with no kinks	3
		M	All pipe installed in vertical and horizontal planes and the pipe welded	
		M	Installed pipework does not rub on any components when operating	
		M	High pressure line is securely fastened using approved method	
		M	Nitrogen used to make all brazed connections	
		M	Are both Ball valves installed as specified per drawing	
		J	Brazed joint #3 is acceptable (copper to copper)	
B6	Module B - Pressure Test			0
				1
				2
				3
		J	Is brazed joint _____ on Hotgas By-Pass acceptable	0
				1
				2
B7	Module B - Evacuation			3
		M	Starting pressure of all attempts meet required standards	
		M	The appropriate valves were opened to ensure pressure testing completed	
		M	Gauges were correctly fitted to the system	
		M	Nitrogen was safely added to the system to the desired test pressure	
		M	System was leak tested while under pressure	
		M	No leaks were detected on FIRST pressure test attempt	
		M	System held pressure for complete standing time after any leaks	
		M	Nitrogen was safely released from system at completion of pressure test	
		M	Vacuum level (value) of all attempts meet required standards	
		M	The appropriate valves were opened to ensure evacuation of the system	
		M	Vacuum gauge installed so it can be isolated from the vacuum pump	
		M	The vacuum held when isolated from the vacuum pump for 10 minutes	
		M	The vacuum held when isolated from the vacuum pump for 10 minutes	

Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score
C1	Module B - Connect the Electrical Circuit	M M M M M M M M M M M M	All wiring installed as per supplied wiring diagram Supply voltage is wired correctly on supplied plug 220V supply wired to correct terminals in switchboard, and correct Compressor wired to correct terminals in switchboard and unit, by Supply voltage and contacts to A-421 thermostat (Heat recovery Supply voltage and contacts to A-421 thermostat (Ice rink wired c Low Pressure control wired to correct terminals in switchboard and High Pressure control wired to correct terminals in switchboard a All cables saddled (fixed), and secured separate to piping Installed cables not be crushed by piping or other components Installed cables and wires installed as per test project for adequa All cables and conduit is installed within the boundaries of the sup	
C2	Module B - Connect the Electronic Controls (The	M M M	Temperature probe is wired to the correct terminals in thermostat Temperature probe is installed correctly Cable channel is vertically and horizontally leveled and securely fa	
C3	Module B - Electrical Testing	M M M M M M M M M	Installation tested for earth continuity to power supply Installation tested for earth continuity to compressor prior to ener Installation tested for earth continuity to solenoid valves Installation tested for earth leakage prior to energising Installation tested for shorts between active and neutral prior to e No wiring faults found on circuit testing Circuit energised safely the first time without blowing fuses/circuit Circuit operated safely and correctly the first time without wiring r Circuit operated safely and correctly after any necessary modifica	
Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score

D1	Module B - Charge with Refrigerant Primary Circ	M	Gas manifold valves in correct position prior to operation
		M	All mechanical valves in correct position prior to operation
		M	Liquid refrigerant was added to the liquid line only (not suction)
		M	The correct refrigerant charge weighed into the system and recorded
		M	Amount of refrigerant added is within acceptable guidelines
		M	Electronic leak check was made during charging of refrigerant
		M	The gauges were removed from the system with no avoidable loss
D3	Module B - Commissioning Report	M	Commissioning report - ambient temperature recorded correctly
		M	Commissioning report - refrigerant type recorded correctly
		M	Commissioning report - refrigerant charge recorded correctly
		M	Commissioning report - suction pressure recorded correctly
		M	Commissioning report - discharge pressure recorded correctly
		M	Commissioning report - condenser subcooling recorded correctly
		M	Commissioning report - total system superheat recorded correctly
		M	Commissioning report - LP control cut in and cut-out are set and recorded
		M	Commissioning report - HP control cut out is set and recorded correctly
		M	Commissioning report - Capacity regulator set and recorded correctly
D4	Module B - Commissioning - Complete the Insta	M	Commissioning report - compressor operating current measured
		M	Project completed requiring no additional materials
		M	Covers installed securely on all equipment
		M	No burn marks and no damage on any equipment from installation
		M	System left operational at completion of module
		M	After minimum 12hrs run time there is NO water present above the
		M	The Thermostat was correctly programmed for reheat
		M	The Thermostat was correctly programmed for Ice rink
D5	Module C - Commissioning Report	M	Commissioning report - ambient temperature measured and recorded
		M	Commissioning report - return air temperature dry bulb measured
		M	Commissioning report - supply air temperature dry bulb measured
		M	Commissioning report - Indoor fan speed and mode of operation
		M	Commissioning report - refrigerant type and refrigerant charge recorded
		M	Commissioning report - suction pressure measured and recorded
		M	Commissioning report - total system superheat measured and recorded
D6	Module C - Commissioning - Complete the Insta	M	Commissioning report - compressor current draw measured and recorded
		M	Project completed requiring no additional materials

		M M M M	Covers installed securely on all equipment No burn marks on any equipment from installation Installation not damaged in any way System left in correct operation	
Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score
E1	Module C - Electrical Fault Finding	M M M M M M M M	Was the compressor capacitor tested correctly and resault recor Were the compressor windings identified correctly and recorded Was the unite tested for short circuit Was the unite tested for earth continuity The fault was correctly identified under 30 minutes The fault was correctly identified under 60 minutes The fault was correctly identified under 75 minutes Is the fault repaired and the system fonctionnal (operating)	
Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score
F1	Module C - Refrigeration system repair	M M M M M M M M J	Flared made to acceptable standards Expantion (Swage) made to proper depth Tubing reamed properly Noitrogen was used while brazing Pressure tested repaired and check with soap and did not leak or All covers, caps, screws etc. put back on the unite Insulation not damaged Is the system repaired and fonctionnal (operating) Brazing joint is made to acceptable standards	0 1

				2 3
Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score
G1	Module C - Reclaim Refrigerant	M M M M M M M M M M M M M	Power supply to air conditioner was isolated before refrigerant re Service manifold gauge lines were fitted to the system in the corr Moisture contamination was prevented without loss of refrigerant The correct refrigerant cylinder was selected for the recovery of r Refrigerant cylinder weighed and recorded before recovery starte Refrigerant recovery lines set up was correct first time The full refrigerant charge was removed from the system using re Electronic leak check was made during recovery of refrigerant System pressures were at atmospheric pressure or below after re All service caps replaced on the recovery unit and recovery cylind The quantity of refrigerant recovered from the system was record Filter drier installed in the correct flow direction Refrigerant was purged from recovery unite	
G2	Module C - Evacuation	M M	First vacuum attempt meets required standards The vacuum held when isolated from the vacuum pump for 10 m	
G3	Module C - Charge with Refrigerant	M M	The correct refrigerant charge weighed into the system (recorded The gauges were removed from the system with minimal loss of	
Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score
H1	Module A - Work Practices and Safety	M M	Protective gloves were worn at all times when exposed to heat so Protective eye wear was worn at all times while brazing	

H2	Module B - Work Practices and Safety	M	The competitor always used the correct tool and safe work practice	
		M	The competitors brazing torches and regulators are left at atmospheric pressure	
		M	Protective gloves were worn at all times when exposed to heat sources	
		M	Protective eye wear was worn at all times while brazing, drilling, heating	
H3	Module C - Work Practices and Safety	M	The competitor always used the correct tool and safe work practice	
		M	The competitors brazing torches and regulators are left at atmospheric pressure	
		M	Protective gloves were worn at all times when exposed to heat sources	
		M	Protective eye wear was worn at all times while brazing, drilling, heating	
		M	The competitor always used the correct tool and safe work practice	
		M	The competitors equipment was in a safe condition on completion	
Sub Criteria ID	Sub Criteria Name or Description	Aspect Type M = Meas J = Judg	Aspect - Description	Judg Score

Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark
Yes	Refer drawing R00	2	1.00
Yes		2	0.75
Yes	2mm +-	4	0.75
Yes	2mm +-	4	0.75
Yes	2mm +-	4	0.75
Yes	see standard	4	0.50
Yes	see standard	4	0.50
Yes	Pressure tested to	4	1.25
Yes		4	0.75
Yes		4	0.50
		4	0.75
Performance below industry standards			
Performance meets industry standards			

Criterion A Total Mark 12.50

Yes	Back plates and co	3	0.20
Yes	Refer drawing R00	3	0.50
Yes	Refer drawing R00	3	0.40
Yes	Refer drawing R00	1	0.30
Yes	2 mounting points	4	0.20
Yes	Refer to standard s	4	0.20
Yes	Refer to standard s	4	0.40
Yes	Refer to standard s	4	0.30
Yes		1	0.20
Yes	Refer to standard s	4	0.30
Yes	Refer to standard s	4	0.20
Yes		3	0.20
		4	0.80
Performance below industry standards			
Performance meets industry standards			
Performance meets industry standards and surpasses that			
Excellent or outstanding performance relative to industry e		4	1.00
Performance below industry standards			
Performance meets industry standards			
Performance meets industry standards and surpasses tha			
Excellent or outstanding performance relative to industry e			
Yes	Refer to standard s	4	0.40
Yes	Refer to standard s	4	0.30
Yes		1	0.20
Yes	Refer to standard s	4	0.30
Yes	Refer to standard s	4	0.20
		4	0.80
Performance below industry standards			
Performance meets industry standards			
Performance meets industry standards and surpasses that			
Excellent or outstanding performance relative to industry e		4	1.00
Performance below industry standards			
Performance meets industry standards			
Performance meets industry standards and surpasses tha			

Excellent or outstanding performance relative to industry e			
Yes	Refer to standard s	4	0.40
Yes	Refer to standard s	4	0.20
Yes		1	0.20
Yes	Refer to standard s	4	0.30
Yes	Refer to standard s	4	0.20
Yes	Refer drawing R00	4	0.50
		4	0.80
Performance below industry standards			
Performance meets industry standards			
Performance meets industry standards andsurpasses that			
Excellent or outstanding performance relative to industry e		4	1.00
Performance below industry standards			
Performance meets industry standards			
Performance meets industry standards andsurpasses that			
Excellent or outstanding performance relative to industry e			
Yes	Refer standards se	3	0.50
Yes	All isolation valves	1	0.50
Yes		4	0.20
Yes	Refer test project i	4	0.40
Yes	Soapy water or sup	4	0.20
Yes	test project	4	1.50
Yes	Refer standards se	4	0.50
Yes	Refer standards se	4	0.20
Yes	Refer standards se	3	0.50
Yes		1	0.20
Yes		4	0.20
Yes	Refer standards se	4	1.50
Yes	Refer standards se	4	0.50

Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark
Yes	Refer R007, R008,	2	1.50
Yes	Refer R007, R008,	4	0.50
Yes	Refer R007, R008,	4	0.50
Yes	Refer R007, R008,	4	0.50
Yes	Refer R007, R008,	4	0.50
Yes	Refer R007, R008,	4	0.50
Yes	Refer R007, R008,	4	0.50
Yes	Refer R007, R008,	4	0.50
Yes	Every 400mm mm	4	0.40
Yes		4	0.40
Yes	conduit or double i	3	0.40
Yes	front or rear of crac	3	0.20
Yes	Refer R007, R008,	4	0.50
Yes		3	0.40
Yes	Every 400mm max	4	0.40
Yes	Refer standards se	5	0.30
Yes	Refer standards se	5	0.30
Yes	Refer standards se	5	0.30
Yes	Refer standards se	5	1.00
Yes	Refer standards se	5	1.00
Yes		3	1.00
Yes		3	1.50
Yes		3	1.50
Yes		3	0.40
Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark

Criterion C Total Mark 15.00

Criterion D Total Mark 17.50

Yes	All isolation valves	3	0.20
Yes	All isolation valves	3	0.30
Yes		3	0.50
Yes	R134a vapour or li	3	1.00
Yes	Agree on acceptab	3	0.50
Yes	Refer standards se	3	0.50
Yes	Refer standards se	5	0.50
Yes	Refer test project	5	0.30
Yes	Refer test project	5	0.30
Yes	Refer test project	5	0.30
Yes	Refer test project	5	0.50
Yes	Refer test project	5	0.50
Yes	Refer test project	5	0.50
Yes	Refer test project	5	0.50
Yes	Refer test project	5	0.80
Yes	Refer test project	5	0.80
Yes	Refer test project	5	0.80
Yes	Refer test project	5	0.30
Yes	Refer to test projec	1	0.30
Yes	Refer to test projec	1	0.20
Yes	Refer to test projec	1	0.90
Yes	Refer to test projec	1	0.50
Yes	Refer to test projec	2	1.00
Yes	Refer to test projec	5	0.50
YES	Refer to test projec	5	0.50
Yes		5	0.20
Yes		5	0.50
Yes		5	0.50
Yes		5	0.40
Yes		5	0.50
Yes		5	0.50
Yes		5	0.40
Yes		5	0.40
Yes		1	0.10

Yes		1	0.20
Yes		1	0.20
Yes		1	0.20
Yes		1	0.40
Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark
Yes		6	1.00
Yes		6	1.00
Yes		6	1.50
Yes		6	1.50
Yes		6	1.00
Yes		6	0.50
Yes		6	0.50
Yes		6	1.00
Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark
Yes		6	2.00
Yes		6	1.00
Yes		6	1.00
Yes		6	1.00
Yes		6	1.00
Yes		6	1.00
Yes		6	1.00
Yes		6	1.00
Yes		6	1.00
Performance below industry standards			
Performance meets industry standards			

Criterion E Total Mark 8.00

Criterion F Total Mark 10.00

Performance meets industry standards and surpasses that of the industry
 Excellent or outstanding performance relative to industry e

Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark
Yes	Refer to standards	5	0.50
Yes		5	0.50
Yes		5	0.50
Yes		5	0.20
Yes		5	0.50
Yes		5	1.00
Yes		5	1.00
Yes		5	0.20
Yes		5	0.50
Yes		5	0.80
Yes		5	0.50
Yes		5	0.50
Yes		5	0.50
Yes		5	0.50
Yes		5	0.50
Yes	Refer to standards	3	1.00
Yes	Refer to standards	4	1.00
Yes	Refer to standards	3	2.00
Yes		5	0.80
Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark
Yes		1	0.25
Yes		1	0.25

Criterion G Total Mark 12.00

Criterion H Total Mark 5.00

Yes		1	0.25
Yes		1	0.25
Yes		1	0.50
Yes		1	0.50
Yes		1	0.50
Yes		1	0.50
Yes		1	0.50
Yes		1	0.50
Yes		1	0.50
Yes		1	0.50
Extra Aspect Description (Meas or Judg) OR Judgement Score Description (Judg only)	Requirement or Nominal Size (Measurement Only)	WSSS Section	Max Mark

Criterion I Total Mark 0.00

Competition Total Mark 100.00